

Maine Department of Public Safety Office of the State Fire Marshal 52 State House Station Augusta, Maine 04333-0052

(207) 626-3880 Telephone
 (207) 287-6251 Fax
http://www.maine.gov/dps/fmo/index.htm

Application for a Permit for Aboveground Storage of Flammable and Combustible Liquids

Requirements for aboveground storage of flammable and combustible liquids are in Title 25 MRSA §2481, et seq., 16-219 CMR Chapter 34 Rules and Regulations for Flammable and Combustible Liquids, NFPA 30 Flammable and Combustible Liquids Code, NFPA 30-A Code for Motor Fuel Dispensing Facilities and Repair Garages, NFPA 385 Standard for Tank Vehicles for Flammable and Combustible Liquids and NFPA 409 Standard for Air craft Fuel Servicing.

The application fee, \$15 per site, must be submitted with the application.

Keep a copy of the application, plans, and specifications for your records.

The permit must be issued before any action to construct the facility is taken. Be sure the permit will be issued BEFORE you spend money! People have been "stuck" because they bought something that could not be approved. Along with what they had pa9id for the non-conforming tanks and equipment, they had to pay for the compliant tanks and equipment.

Submit Construction Plans including a Site Plan and an Elevation Plan (end and side views) prepared specifically for this installation with this application. The plans submitted are the plans to be used to construct the facility. The facility must be constructed according to the plans and specifications approved by the Office of the State Fire Marshal.

Changing the plans without prior written approval voids a permit issued for a facility.

There are specific requirements for a building or structure to house or protect an aboveground storage tank. Plans and specifications for a building or structure MUST be submitted with the application. Constructing a building or structure not included on the application will void the permit issued according to the application submitted.

Any changes to the plans and specifications submitted with this application must be approved by the Office of the State Fire Marshal prior to their implementation and a copy of the "As Built" plans must be submitted when the original plans and specifications are changed.

The Office of the State Fire Marshal will submit this application to the Maine Department of Environmental Protection to determine compliance with the Wellhead Protection requirements of Title 38 MRSA §1391 prior to its review of the application.

Application for a permit issued under the Permit by Rule program established pursuant to HP 206-LD 253 must be made on an application specific to that program. A permit for a facility that varies in any way from the Permit by Rule process must be made on this application.



Maine Department of Public Safety Office of the State Fire Marshal 52 State House Station Augusta, Maine 04333-0052

(207) 626-3880 Telephone
(207) 287-6251 Fax
http://www.maine.gov/dps/fmo/index.htm

Application for a Permit for
Aboveground Storage of
Flammable and Combustible Liquids

For Office Use Only:
Permit #
Date Issued:
Action: Approved per Plan Approved per Plan & Inspection Denied
Ву:
Date:
DEP Wellhead
Protection:
☐ Complies
☐Does Not Comply
☐ May Be Made To Comply ☐ Waiver Requested
1
Fee: Amount: \$
Amount · y
Date Rcd:
Check #:
DEP Registration #:

			I	Date Rcd:
				Check #:
Facility:				CHECK #.
Facility Name:				DEP Registration #:
Physical Address:				DEP Registration date:
City:				County:
Contact:	Telephone:		Email:	
Total Capacity of Facility:	<u> </u>	US G		
Plans and Specifications must be certified by a Profe	essional Engineer if T	otal Capacity of th	e Facility is grea	ter than 1320 gallons.
Owner of Tank:				
Name:				
Mailing Address:				
City:		State:		Zip/Postal Code:
Contact:	Telephone:		Email:	
Permit will be issued to "Owner o	f Tank" as sho	wn above.		
	wner of Tank			
Name:				
Mailing Address:				
City:	State:			Zip/Postal Code:
Contact:	Telephone:		Email:	-
Engineer's Certification:				

__, hereby certify that the facility

Signature

described on this application is designed according to recognized engineering practices, industry standards, statutes, rules, codes,

and standards.

Engineer's

Seal

Facility:	Town:	Application Date:		
<pre>Type of Application: New Aboveground Storage Facility (No existing permit) Change of facility (Attach a copy of existing permit)</pre>				
Use of Facility:				
Wholesale Oil (Bulk Plant) Retail Oil (Service Station, Convenience Store, Marina, Airport, etc) Private Fueling Single Family Dwelling	Multiple Family Dwel (Including Nursing Homes) Public Facilities (In Places of Assembly) Chemical Storage Industrial	State Facility		
DEP Wellhead Protection:				
Yes No 1. Was the tank facility inst 2. Will the facility be used 3. Is the facility replacing September 30, 2008 that is 4. Is the facility replacing	talled before September 30, solely to store heating oi an aboveground oil storages on the same property? or expanding an undergroun 008 and is presently on the	1 that is consumed on site, not resold? facility that was installed before d oil storage facility that was registered on		
Section A-2				
If you answered "No" to all the questions in A-1, complete this section. 1. Will any portion of the facility be installed after September 30, 2008? (If "No", Section A-2 does not apply to the tank(s) you are installing.) 2. Will any portion of the facility be located within 300 feet of a private well or water supply? (This does not include a private well located on the same lot as the facility and serving only users living on that property.) 3. Will any portion of the facility be located within the source water protection area of a public drinking water well mapped by the Department of Human Services or within 1000 feet of a public water well, whichever is greater? Maps of source water protection areas are available on the internet at www.maine.gov/dhs/eng/water/index.htm . Public water supplies are defined as any well or water supply where water is obtained, sold, furnished, or distributed to the public for human consumption. The well or water supply must meet one or more of the following requirements to be a public water supply: • Serves more than 15 connections, OR • Regularly Serves at least 25 individuals daily for at least 60 days of the year, OR • Provides bottled water for sale where the water is pumped from on site.				
 □ 4. Does the well or water supply serve a school or community water supply system? (A school is an institution for the formal classroom instruction of children in grades k-12. A community water system is a public water system that serves at least 15 service connections used by year-round residents or regularly serves at least 25 year-round residents.) □ 5. Will any portion of the facility be located within a mapped significant sand and gravel aquifer? As of July 1, 2010, Maine law prohibits installation of ASTs within significant sand and gravel aquifers mapped by the Maine Geological Survey unless a variance is obtain from the Department of Environmental Protection (DEP). 				
If the answer to #2 or #4 above is unless the applicant proves there is no supply at issue. Contact DEP at (207) if a hydrogeologic connection exists. If the answer to #3 is "Yes" and to be granted upon written application to exceed minimum regulatory requirements drinking water contamination. If the answer to #5 is YES, Please if a variance may be applicable for the	s "Yes", a new aboveground on hydrogeologic connection 287-2651 to obtain informathe answer to #4 is "No", to DEP if DEP determines that and will effectively minimate review Chapter 692, Section proposed site. Contact Dew, please call David McCask	till or George Seel at (207) 287-2651 or visit		

Tank # Page 1 of 2, set of					
Tank Information:					
Owner of Tank:	Owner Start Date:				
Operator of Tank:	Operator Start Date:				
Use of Tank:	<u> </u>				
Public Fueling					
☐Automotive ☐Aviation ☐Marina ☐	Equipment Other:				
Private Fueling	——————————————————————————————————————				
	Equipment Other:				
Equipment Supply (Specify):					
Container Storage					
Fuel Production Facility					
Other (Specify):	1				
Nominal Capacity:	Manufacturer of Tank:				
US Gallons	Out and a better of Table				
Tank Material:	Orientation of Tank: Horizontal Vertical				
Steel Other (Specify): Tank Listing:	- Notizonear - Vereicar				
Tul 80	'ank				
UL 142 UL 2085 Fire Resist	ant Tank				
☐UL 142 with Secondary ☐UL 2085 Tank in Vau	ılt				
Containment Other (Specify):					
Type of Secondary Containment:					
Double Wall Tank	□Dike, Metal □Remote Impoundment				
Dike, Earth with Impervious Lining	None				
Capacity of Dike or Remote Impoundment:	US Gallons				
Vault					
Yes No Is the tank in a vault? (A concrete se					
☐Yes ☐No If the tank is in a vault, is the vault					
If the vault is listed, specify the lis	ting:				
☐ Inside a building Submit plans and specifications	for the building with this application!				
(More than 50% of wall space is enclosed. Building					
publications)					
Roof with walls (Less than 50% of wall space, incl	uding dike walls, is enclosed.)				
☐Roof Only☐None					
Electrical Wiring and Equipment:					
Yes No None Are electrical wiring and electrical equipment within the hazard area defined by the					
National Electrical Code, NFPA70, and NFPA 30, installed in compliance with these codes?					
Flood Zone Yes No is the tank in a flood zone?					
Collision Protection:					
Barricades					
Bollards					
Other (Specify):					
Security: Chain Link Fence Enclosure, no less than 6 feet hi	gh. 10 feet from tank.				
Entire property is fenced.	gir, 10 1000 110m daini.				
Other (Specify):					
Distance from tank to:					
	er Tanks:				
	Less than 3 feet pensers:				
	Public Fueling No less than 50 feet				
	Private Fueling				
No less than 25 feet					
Opposite Side of a Public Way: Propane Storage No less than 25 feet No less than 20 feet					
No less than 25 feet No Leak Detection (Tank):	TESS CHAN 20 TEEC				
None Electronic/Gro	und Water				
Automatic Tank Gauge	or Groundwater Sampling				
Manual Monitoring/Secondary Containment	☐Statistical Inventory Analysis				
Other (specify):					

Facility: _____ Application Date: _____

Tank # Page 2 of 2, Set of				
Chamber Information:	Chamber 1	Chamber 2	Chamber 3	
Capacity				
Product Use generic name, not trade name.	US Gallons Alcohol Antifreeze Asphalt Biodiesel B-1 B-74 Biodiesel B-75 B-99 Biodiesel B-100 Crude Oil Diesel Fuel #2 Fuel Gasoline, Aviation Gasoline, Leaded Gasoline, Plus Gasoline, Premium Gasoline, Regular Jet Fuel Kerosene Motor Oil Vegetable Oil Other (Specify):	US Gallons Alcohol Antifreeze Asphalt Biodiesel B-1 B-74 Biodiesel B-75 B-99 Biodiesel B-100 Crude Oil Diesel Fuel #2 Fuel Gasoline, Aviation Gasoline, Leaded Gasoline, Plus Gasoline, Premium Gasoline, Regular Jet Fuel Kerosene Motor Oil Vegetable Oil Other (Specify):	US Gallons Alcohol Antifreeze Asphalt Biodiesel B-1 B-74 Biodiesel B-75 B-99 Biodiesel B-100 Crude Oil Diesel Fuel #2 Fuel Gasoline, Aviation Gasoline, Leaded Gasoline, Plus Gasoline, Premium Gasoline, Regular Jet Fuel Kerosene Motor Oil Vegetable Oil Other (Specify):	
Marking: Product Name NFPA 704 Hazard Health (blue) Flammability (red)				
Instability (Yellow) Special Hazards (white)	 ☐Yes ☐No	 ☐Yes ☐No	 ☐Yes ☐No	
"No Smoking" Is Product Under Pressure?	∏Yes ∏No	∏Yes ∏No	∏Yes ∏No	
Normal Vent (Size & Type) Class IA normally Closed Class IB, IC normally closed or flame arrestor Normal Vent (Height Above Ground) Class I No less than 12 feet above ground Emergency (Vent Size & Type) Emergency vent for Primary Chamber Emergency (Vent Size & Type) Emergency Vent for Interstitial Space Type of Overfill Protection	Level Gauge Vent Whistle Drop Tube Electronic Mechanical Mech + Elect None	Level Gauge Vent Whistle Drop Tube Electronic Mechanical Mech + Elect None	Level Gauge Vent Whistle Drop Tube Electronic Mechanical Mech + Elect None	
Does the Fill Pipe terminate within 6" of the bottom of the tank?	□Yes □No	☐Yes ☐No	□Yes □No	
Type of Pump	☐Pressure ☐Suction ☐	☐Pressure ☐Suction ☐	☐Pressure ☐Suction ☐	
Is the product heated? Is the product under pressure?	Yes No	Yes No	Yes No	
Piping Information: Is any of the piping underground? Piping Material: Leak Detection (Piping): None Automatic Tank Gauge Manual Monitoring/Secondary Containment Other (specify):	Yes No Steel Other round Water El apor Gr	(specify): ectronic/Secondary Cooundwater Sampling atistical Inventory A	ontainment	

Facility: _____ Application Date: _____

Site Plan (These are the plans to be used to install the facility!)				
Show the Location of All of Tanks and Dikes Buildings Property Lines Public Ways Dispensers Propane Storage Security Features Collision Protection	the Following on this Plan: Electrical Controls and Equipment	Show the Distance from the Tanks to the following on this plan: Buildings Property Lines Public Ways Other Tanks Dispensers Propane Storage	Indicate NORTH With arrow	

Facility: ____ Town: ____ Application Date: ____

Elevation Plan (Side and End Views) (These are the plans to be used to install the facility!)					
Show All of the Following or Base Material Ground & Foundation Secondary Containment Construction Material Inside Dimensions and Capacity Drain & Valve Tanks Tank Supports Normal Vents Type and Size Height Above Ground Supports		□Loading Dock □Vehicle Containment □Bonding Connection □Self-Closing Valves □Protection □Fire Extinguishing Equipment □From Collision □From Flooding □From Tampering □Electrical Equipment □Emergency Disconnects	☐Marking ☐Product Name ☐Hazard Classification ☐Flammable ☐Combustible ☐Other: ☐NFPA 704 ☐DOT Placard ☐Color Code ☐On Tanks ☐On Piping		

Facility: _____ Application Date: _____